# **Energy Star Homes Evaluation**

Location: Denver, CO

**Energy Star Rating: 83.7** 

NG THE EARTH. SAVING YOUR M

# **Energy Related Characteristics For Cold Climates Typical 3 Bedroom Frame House**

**Heating System** Gas Furnace, 80 AFUE

> **Cooling System** None

Water Heating System Gas Water Heater, 0.56 EF

Duct Leakage 10%(CFM25<sub>Total</sub>=105)

**Estimated Infiltration** 7.0 ACH @ 50 pascal's

Areas (sq.ft.)

Condition floor -1050 Windows -126 Ceiling Area -1050 Insulated Ex. Wall -1010 (net)

#### Insulation

Ceiling: R-30 R-13+1" Rigid Walls: Floor: R-19 Batt R-6 Ducts:

Windows

Double Clear-Vinyl Frame U-Value=0.49 SHGC=0.56

#### **Energy Evaluation Results**

Estimated Annual Energy Use: 70.1 MBtu Estimated Annual Energy Cost: \$834

The Energy Star program awards the "Energy Star Home" designation to homes scoring 86 points or more on the Home Energy Rating Scale (HERS). A score of 86 indicates that a home is 30% more efficient than a standard reference home which scores an 80. Implementing one of the Energy Star packages below would bring this home's score up above 86. You may also request evaluation of other improvements or packages of improvements. Annual energy costs are calculated using an electric rate of \$0.08/kWh and a gas rate of \$0.50/Therm.

#### **Energy Star Package 1 HERS Score = 86.1**

Estimated Annual Energy Cost = \$773 Estimated Annual Saving =\$61

- Wall: R-19+2" Rigid Insulation 1.
- Windows: Double Pane/LowE/Argon 2. 2. Fill/Vinyl Frame U=0.36 SHGC=0.52
- 3. Attic: Increase To R-38
- Duct Leakage: 3% (CFM25<sub>Total</sub>= 31.5) 4.

# **Energy Star Package 2** HERS Score = 86.2

Estimated Annual Energy Cost =\$768 Estimated Annual Saving =\$66

Wall: R-15+2" Rigid Insulation Heating: Furnace, 95AFUE

1.

### **Energy Star Package 3** HERS Score = 87.3

Estimated Annual Energy Use =63.6 MBtu Estimated Annual Energy Use =63.0 MBtu Estimated Annual Energy Use =61.5 MBtu Estimated Annual Energy Cost = \$753 Estimated Annual Saving =\$81

> 1. Heating: Furnace, 95AFUE

2. Water Heating: Gas Instantaneous, 0.65EF

## **Produced by:**

Florida Solar Energy Center 1679 Clearlake Road, Cocoa, Florida 32922 Fax: (321)638-1439

Janet McIlvaine Phone: (321) 638-1434 E-mail: janet@fsec.ucf.edu Matthew Lombardi Phone: (321)638-1421 E-mail: mlombardi@fsec.ucf.edu

General Guidance for ENERGY STAR Homes for Habitat for Humanity Location: Denver, CO (Cold) HDD = 6,023; CDH = 5,908				
Building Component	Base Case House <sup>1</sup> HERS Rating = 83.7	Proposed Changes	Potential Point Value <sup>2,3</sup> of proposed Change	Cost
Frame Floor Insulation	R-19 Batt	Increase to R-30 Batt	0.5	
Wall Insulation	R-13+1" Rigid	R-13+2" Rigid Insulation	0.8	
		R-15 No Rigid Insulation	-0.5	
		R-15+2" Rigid Insulation	0.8	
		R-19 No Rigid Insulation	0.2	
		R-19+2" Rigid Insulation	1	
Windows	Double Clear-Vinyl Frame	Double Pane/LowE/Argon Fill/Vinyl Frame#1, U=0.32 SHGC=0.3	0.8	
		Double Pane/LowE/Argon Fill/Vinyl Frame#2, U=0.36 SHGC=0.52	0.7	
Attic Insulation	R-30	Increase to R-38	0.3	
		Increase to R-50	0.5	
Heating Equipment	Gas Furnace, 80AFUE	Furnace, 95AFUE	1.9	
Water Heating Equipment	Gas Water Heater, 0.56EF	Gas Instantaneous, 0.65EF	1.6	
		Gas Tank, 0.56EF, R-5 tank insulation	0.5	
		Elec Tank, 0.9EF	-0.1	
Duct Leakage	10% (CFM25 <sub>Total</sub> = 105) <sup>(4)</sup>	3% (CFM25 <sub>Total</sub> = 31.5) <sup>(4)</sup>	0.3	

<sup>1</sup> Typical 3 bedroom home described on the "Energy Star Homes Evaluation" for this location.

<sup>2</sup> Indicates change in HERS ENERGY STAR rating with each enhancement incorporated individually into the Habitat Home. A score of 86 qualifies

a home for ENERGY STAR status and indicates 30% saving in combined heating, cooling, and water heating energy use compared to a standard Reference Home.

<sup>3</sup> IMPORTANT: Potential Point Values are not additive. Combinations must be evaluated by a Certified Rater to verify effective score.

<sup>4</sup> Duct leakage is shown as a % of conditioned floor area. For example, if CFM25=65, then leakage = 65/1050 = 6.2%.

#### Produced By:

Florida Solar Energy Center 1679 Clearlake Road Cocoa, Florida 32922 Fax: (321) 638-1439 Janet McIlvaine Phone: (321) 638-1434 Email: Janet@fsec.ucf.edu Kevin McCluney Phone: (321) 638-1000, ext 1222 Email: KMcCluney@fsec.ucf.edu Matthew Lombardi Phone: (321) 638-1421 Email: Mlombardi@fsec.ucf.edu