# **Energy Star Homes Evaluation**

Location: Roanoke, VA

**Energy Star Rating: 84.6** 



## **Energy Related Characteristics For Mixed Climates Typical 3 Bedroom Frame House**

**Heating System** Areas (sq.ft.)

Gas Furnace, 80 AFUE Condition floor -1050 Windows -126 **Cooling System** Ceiling Area -1050 A/C, 10 SEER Insulated Ex. Wall -1010 (net)

**Water Heating System** Gas Water Heater, 0.56 EF

R-13+1" Rigid Walls: Floor: R-19 Batt **Duct Leakage** 10% (CFM25<sub>Total</sub>=105) Ducts: R-6

**Estimated Infiltration** 7.0 ACH @ 50 pascal's

Windows Double Clear-Vinyl Frame U-Value=0.49 SHGC=0.56

Insulation

R-30

Ceiling:

#### **Energy Evaluation Results**

Estimated Annual Energy Use: 63.8 MBtu Estimated Annual Energy Cost: \$829

The Energy Star program awards the "Energy Star Home" designation to homes scoring 86 points or more on the Home Energy Rating Scale (HERS). A score of 86 indicates that a home is 30% more efficient than a standard reference home which scores an 80. Implementing one of the Energy Star packages below would bring this home's score up above 86. You may also request evaluation of other improvements or packages of improvements. Annual energy costs are calculated using an electric rate of \$0.08/kWh and a gas rate of \$0.50/Therm.

## **Energy Star Package 1** HERS Score = 86.1

Estimated Annual Energy Use =60.5 MBtu Estimated Annual Energy Use =59.6 MBtu Estimated Annual Energy Cost = \$785 Estimated Annual Saving =\$44

- Windows: Double Pane/LowE/Argon 1. Fill/Vinyl Frame#2, U=0.32 SHGC=0.3
- Attic: Increase to R-38
- Duct Leakage: Reduce Duct Leakage To 3%(CFM25<sub>Total</sub>=31.5)

## **Energy Star Package 2** HERS Score = 86.2

Estimated Annual Energy Cost =\$789 Estimated Annual Saving =\$40

Water Heating: Gas Instantaneous,

## **Energy Star Package 3** HERS Score = 86.0

Estimated Annual Energy Use =60.8 MBtu Estimated Annual Energy Cost = \$801 Estimated Annual Saving =\$28

1. Heating: Furnace, 95 AFUE

#### **Produced by:**

Florida Solar Energy Center Janet McIlvaine Matthew Lombardi 1679 Clearlake Road, Cocoa, Florida 32922 Phone: (321) 638-1434 Phone: (321)638-1421

Fax: (321)638-1439 E-mail: janet@fsec.ucf.edu E-mail: mlombardi@fsec.ucf.edu

### General Guidance for ENERGY STAR Homes for Habitat for Humanity

Location: Roanoke, VA (Mixed)

HDD = 4.321; CDH = 9.275

Building Component	Base Case House <sup>1</sup>	Proposed Changes	Potential Point Value <sup>2,3</sup>	Cost
	HERS Rating = 84.6		of proposed Change	
Frame Floor Insulation	R-19 Batt	Increase to R-30 Batt	0.3	
Wall Insulation	R-13+1" Rigid Insulation	R-13 No Rigid Insulation	-0.5	
		R-15 No Rigid Insulation	-0.4	
		R-15+1" Rigid Insulation	0.1	
Windows	Double Clear-Vinyl Frame	Double Pane/LowE/Argon Fill/Vinyl Frame#1, U=0.32 SHGC=0.3	0.9	
		Double Pane/LowE/Argon Fill/Vinyl Frame#2, U=0.36 SHGC=0.52	0.6	
Attic Insulation	R-30	Increase to R-38	0.2	
		Increase to R-50	0.4	
		R-30 + Radiant Barrier	0.2	
Heating Equipment	Gas Furnace, 80AFUE	Furnace, 95AFUE	1.4	
Cooling Equipment	A/C, 10 SEER	Increase to 12 SEER	0.7	
Water Heating Equipment	Gas Water Heater, 0.56EF	Gas Instantaneous, 0.65EF	1.6	
		Gas Tank, 0.56EF, R-5 tank insulation	0.5	
		Elec Tank, 0.9EF	0.1	
Duct Leakage	10% (CFM25 <sub>Total</sub> = 105) (4)	3% (CFM25 <sub>Total</sub> = 31.5) <sup>(4)</sup>	0.4	

<sup>&</sup>lt;sup>1</sup> Typical 3 bedroom home described on the "Energy Star Homes Evaluation" for this location.

#### Produced By:

Florida Solar Energy Center 1679 Clearlake Road

Janet McIlvaine Phone: (321) 638-1434 Email: Janet@fsec.ucf.edu Kevin McCluney Phone: (321) 638-1000, ext 1222 Matthew Lombardi Phone: (321) 638-1421

Email: Mlombardi@fsec.ucf.edu

Cocoa, Florida 32922 Fax: (321) 638-1439

Email: KMcCluney@fsec.ucf.edu

<sup>&</sup>lt;sup>2</sup> Indicates change in HERS ENERGY STAR rating with each enhancement incorporated individually into the Habitat Home. A score of 86 qualifies a home for ENERGY STAR status and indicates 30% saving in combined heating, cooling, and water heating energy use compared to a standard Reference Home.

<sup>&</sup>lt;sup>3</sup> IMPORTANT: Potential Point Values are not additive. Combinations must be evaluated by a Certified Rater to verify effective score.

<sup>&</sup>lt;sup>4</sup> Duct leakage is shown as a % of conditioned floor area. For example, if CFM25=65, then leakage = 65/1050 = 6.2%.